

engineering strategies for LEED platinum

Great River Energy



Presented to:

University of Minnesota Power Group

by:

Randy Olson, PE, LEED AP

Scott Rieger, PE, LEED AP

May 19, 2009

introductions



Randy Olson, PE, LEED AP
Mechanical Engineer



Scott Rieger, PE, LEED AP
Electrical Engineer

background owner



- Great River Energy
- 5th Largest electric generation and transmission cooperative in the United States

background goals



- Achieve LEED Platinum
- “...do something with energy efficiency that had never been done before.”

Mike Finley

Director of Business Operations
Great River Energy

background site selection



background team

Architect:

P E R K I N S
+ W I L L

Engineer:

DUNHAM 
mechanical + electrical consulting engineering

background project



- 180,000 sf corporate office
- Data Center
- Full Kitchen and Cafeteria
- Conference Center



mechanical systems



lake source geothermal


vertical ground source vs. lake source

- Both feasible
- Lake option is less costly




lake source geothermal lake study

- Minimal impact
- Less than 1°F change



Winter



Summer

lake source geothermal lake access and use



© 2009 Dunham Associates, Inc. All Rights Reserved

- City owned (not DNR controlled)
- No public access

lake source geothermal

Slim Jim vs. HDPE

- Slim Jim showed good performance
- HDPE more proven over time



lake source geothermal installation details



- Simple
- Serviceable

displacement ventilation (DV) energy efficiency



- Less fan static pressure
- Warmer discharge air temperatures
- Warmer return air temperatures


displacement ventilation indoor air quality (IAQ)



© 2009 Dunham Associates, Inc. All Rights Reserved

- ASHRAE allows reduction in ventilation quantities with DV
- However provided 30% more than code to improve IAQ


displacement ventilation CFD modeling analysis



- Underfloor air flow
- Underfloor delivery temperature
- Space temperature

displacement ventilation synergy with lake system

- Free cooling much of the year
- Sensible only, warmer discharge temps



outside air




- Heat recovery
- Free cooling
- Heat pump
- Dehumidification
- Deliver to fan coil units

mechanical systems other strategies



- Variable speed drives
- Temperature controls
- Measurement and Verification

water efficiency rainwater harvesting



electrical



wind power

location (urban environment)



- City of Maple Grove placed restrictions
- Owner Concerns
 - Safety issues
 - Redundant Ice Sensing

wind power turbine




- Size: 166 ft tall (top of blade)
Rotor diameter of 97 ft
- Unit is a NEG Micon M700
manufactured in Denmark

wind power capacity

- **Great River Energy purchased unit from Energy Maintenance Services (EMS)**
 - Shipped to Gary, SD in 2007 for refurbishment
 - Gearbox was remanufactured
 - Generator was rewound
- **Nameplate data**
 - 200 KW
 - Expected to produce 375,000 kWhr/Yr
- **Total installed cost: (foundation, electrical, etc.)**
 - \$500,000

wind power connection to building/grid




wind power adjustments

- **Wind speed vs. output**
 - >7 – 9mph = Motoring (electricity)
 - 10 – 45mph = Producing
 - \geq 30mph rated output
 - 45mph = Safety cutout
- **Wind Turbine had very inconsistent power factor**
 - Dependent on wind speed
- **GRE installed power factor correction**

wind power

wind power graph




photovoltaic power location



- 72kw PV panels
 - 66kw located on roof
 - 6kw located on ground
- PV panels mounted at 45 degrees
 - Median average of winter/summer sun angle



photovoltaic power technology



photovoltaic power connection to building

- **Inverters (12)**
 - Sunnyboy, 6kw each
 - 277V, 30A breaker in subpanel
- **Shuts down with loss of utility power**



lighting system daylight harvesting

- Ceiling mounted photo sensors
- Fixtures with dimming ballasts




lighting system system design



- Exterior row dimmed separately
 - Measuring light from exterior
- Interior row dimmed individually
 - Measuring light from center atrium
- Center row on/off
- Preset levels

lighting system

interior lighting consumption




lighting system exterior lighting

- **Lower lighting poles**
 - Better able to control light
 - Required more light poles
- **Reduced the wattage of lamps**
 - Achieved same foot-candle levels with 15% less wattage

results

energy savings

- 49% reduction in energy costs
- “Exceptional” calculations required



national awards



- USGBC LEED Platinum
- Consulting Specifying Engineer ARC Gold Award
- ACEC Engineering Excellence Award - Grand Award
- AIA/COTE Top Ten Green Project for 2009



thank you for your time

DUNHAM

50 South Sixth Street / Suite 1100
Minneapolis, Minnesota 55402-1540

PHONE 612.465.7550 FAX 612.465.7551
WEB dunhameng.com EMAIL info@dunhameng.com

mechanical + electrical consulting engineering

